

# PRINCETONIAN ELECTRICITY: MANAGING AN ISOLATED MICROGRID

Saumya Singh

Advised by Prof. Warren B. Powell

The major insights of the thesis are:

- (1) Increasing dispatchable generation decreases demand shortage metrics and percentage of outages.
- (2) Modularization of generation capacity does not necessarily mean greater reliability.
- (3) Battery storage along with dispatchable generation can ensure close to zero demand shortages. Further, increasing dispatchable generation decreases the size of battery required for the microgrid.
- (4) Cost-wise, it is always preferable to have a technology setup with batteries and dispatchable generators rather than without batteries for an isolated microgrid. This is also advisable for reliability reasons.
- (5) The best technological setup for an islanded Princeton University microgrid, given analysis of data from the month of April would be a 0.71MWh battery, two 7MW generators in addition to the existing generation assets. This would have a net present cost in the range of \$55 million - \$85million, depending on financial assumptions made.
- (6) The cost-preferred technology setup would have an LCOE of 7.03 cents/kWh, which is 17% more expensive than the current cost of electrical usage during intermediate demand times.

From a research perspective, the main contributions of the thesis are:

- (1) Establishing a mathematical model for secondary control of an isolated microgrid.
- (2) Providing trends using simulator-generated output on the demand-shortage behavior in isolated microgrids.
- (3) Proposing the cost-optimality of always incorporating battery storage in isolated microgrids if additional dispatchable generation also needs to be included.

Select charts, graphs and key findings are given below:

**1. 3 Additional Generators Considered for Combinations:**

<b>Technical Data (60HZ/720RPM)</b>	<b>Unit</b>	<b>9L34DF <i>small</i></b>	<b>16V34DF <i>medium</i></b>	<b>20V34DF <i>large</i></b>
Power, electrical	MW (kW)	4 (4170)	7 (7430)	9 (9340)
Heat Rate	kJ/kWh	8048	8048	8036
Electrical Efficiency	%	44.7	44.7	44.8
Total Co-gen Efficiency (including HRSG)	%	90.7	90.7	90.8
Ramp Rate	% /min	>100	>100	>100
Start Time (Cold Start)	min	<10	<10	<10
Start Time (Warm Standby)	min	<6	<6	<6
Stop Time (100% to zero)	min	<1	<1	<1

*Table 6-1: Wärtsilä Tri-Fuel Engine Configurations*

**2. Combinations of Additional Generators Considered:**

<b>Setup</b>	<b>Description</b>	<b>Additional Capacity Breakdown</b>	<b>Total Additional Rated Power</b>	<b>Overall Rated Dispatchable Power (excl. solar)</b>
Case 0	No Addition	-	-	15MW
Case 1	Small + Large	4MW + 9MW	13MW	28MW
Case 2	Medium + Medium	7MW + 7MW	14MW	29MW
Case 3	Medium + Large	7MW + 9MW	16MW	31MW
Case 4	Large + Large	9MW + 9MW	18MW	33MW
Case 5	Small + Medium + Large	4MW + 7MW + 9MW	20MW	35MW

*Table 6-2: Combinations of Different Technological Setups*

**3. Summary of Simulation Output for Cases 1 – 5:**







Figure 6-3: (I) Summary of Simulation Output for 5 Technological Setups



(c) Maximum Demand Shortage (MWhr)



(d) Percentage of Outages (%)

Figure 6-3: (II) Summary of Simulation Output for 5 Technological Setups

#### 4. Demand Shortage Statistics

<b>Peak Demand Shortage (MW)</b>						
Scenario	CASE 0: No Addition	CASE 1: 13MW	CASE 2: 7MW+7MW	CASE 3: 9MW+7MW	CASE 4: 9MW+9MW	CASE 5: 9MW+7MW +4MW
Jan-14	11.46	1.31	0.00	0.00	0.31	0.00
Jul-14	24.54	11.54	10.53	7.10	1.21	1.01
Oct-14	18.60	5.37	0.74	0.00	0.00	0.00
Apr-14	15.81	3.36	1.87	2.25	1.68	1.96

<b>Total Demand Shortage (MWhr)</b>						
Scenario	CASE 0: No Addition	CASE 1: 13MW	CASE 2: 7MW+7MW	CASE 3: 9MW+7MW	CASE 4: 9MW+9MW	CASE 5: 9MW+7MW +4MW
Jan-14	2024.97	0.65	0.13	0.13	0.16	0.13
Jul-14	6955.98	384.06	266.24	72.01	0.39	0.24
Oct-14	2890.83	8.20	0.16	0.10	0.10	0.09
Apr-14	2063.49	1.16	1.16	0.64	0.88	0.44

<b>Maximum Demand Shortage (MWhr)</b>						
Scenario	CASE 0: No Addition	CASE 1: 13MW	CASE 2: 7MW+7MW	CASE 3: 9MW+7MW	CASE 4: 9MW+9MW	CASE 5: 9MW+7MW +4MW
Jan-14	637.45	0.50	0.00	0.00	0.03	0.00
Jul-14	3069.16	68.29	54.76	27.20	0.14	0.08
Oct-14	591.42	7.72	0.06	0.00	0.00	0.00
Apr-14	455.93	0.41	0.67	0.27	0.40	0.23

<b>Percentage of Outages* (%)</b>						
Scenario	CASE 0: No Addition	CASE 1: 13MW	CASE 2: 7MW+7MW	CASE 3: 9MW+7MW	CASE 4: 9MW+9MW	CASE 5: 9MW+7MW +4MW
Jan-14	95.89%	0.09%	0.00%	0.00%	0.01%	0.00%
Jul-14	98.53%	14.32%	9.46%	3.74%	0.07%	0.03%
Oct-14	88.86%	0.54%	0.19%	0.16%	0.15%	0.14%
Apr-14	78.96%	0.38%	0.21%	0.14%	0.14%	0.08%

\*Assuming an 'outage' is whenever  $\geq 0.01\%$  of total demand remains unsatisfied.


<b>Peak Overages# (MW)</b>						
Scenario	CASE 0: No Addition	CASE 1: 13MW	CASE 2: 7MW+7MW	CASE 3: 9MW+7MW	CASE 4: 9MW+9MW	CASE 5: 9MW+7MW +4MW
Jan-14	-0.001	-0.001	-0.001	-0.001	-1.724	-0.001
Jul-14	-0.001	-0.001	-0.001	-1.844	-1.282	-1.844
Oct-14	-13.537	-18.372	-19.483	-16.504	-17.666	-15.666
Apr-14	-10.224	-10.998	-9.000	-9.357	-10.998	-8.998

#Assuming an 'overage' is whenever power supply exceeds demand. Displayed as a negative number.

**5. Battery Sizes Required (See Pages 92-98)**

April Setup	Peak Shortage of Demand (MW)	Peak Discharge of Trial 1's Initial Battery (MW)	Trial 1 Initial Battery Size (MWh)	Trial 2 Battery Size (MWh)	Recommended Battery Size (MWh)
Case 0	15.81	15.83	950.00	2012.26	2012.26
Case 1	3.36	3.36	201.60	0.88	0.88
Case 2	1.87	1.87	112.20	0.71	0.71
Case 3	2.25	2.25	134.85	0.38	0.38
Case 4	1.68	1.68	100.77	0.47	0.47
Case 5	1.96	1.96	117.39	0.33	0.33

*Table 6-5: Battery Sizes for April*



*Figure 6-10: Battery Storage Level and Demand for April C1-C5*

**Cost Analysis of Introducing Battery Storage is done using three methods and different financial assumptions (Page 99, page 100 and page 103).**

## 6. LCOE of Adding Battery Storage (Method 2 of Cost Analysis)




Figure 6-12: Levelized Costs for Setups C0-C6 with and without batteries




Figure 6-13: Sensitivity analysis of LCOE with and without batteries